



## Kitemark<sup>™</sup> Certificate

This is to certify that:

The Lawton Tube Company Limited Torrington Avenue Coventry West Midlands CV4 9AB United Kingdom

Holds Certificate Number:

KM 66240

In respect of:

BS EN 13348 Copper and copper alloys - Seamless, round copper tubes for medical gases or vacuum

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Chris Lewis - Certification Director, Product Certification

First Issued: 2002-05-08 Latest Issue: 2019-01-29 Effective Date: 2019-01-29 Expiry Date: 2022-01-28

Page: 1 of 2



...making excellence a habit."

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request. To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated <u>online</u>.

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK. A member of BSI Group of Companies.

## Kitemark<sup>™</sup> Certificate

No. KM 66240

BS EN 13348: 2008 - Copper and copper alloys – Seamless, round copper tubes for medical gases or vacuum

## **Certified Range**

DIAMETER (mm)	WALL (mm)	TEMPER DESIGNATION
12	0.6	HALF-HARD R250
15*	0.7	HALF-HARD R250
22*	0.9	HALF-HARD R250
28*	0.9	HALF-HARD R250
35	1.2	HALF-HARD R250
42	1.2	HALF-HARD R250
54	1.2	HALF-HARD R250
35	1.0	HARD R290
42	1.0	HARD R290
54	1.0	HARD R290
66.7	1.2	HARD R290
76.1	1.5	HARD R290
108	1.5	HARD R290

\*Manufactured under Licence No. KM 66236

Stamped Marking R250: BS EN 13348 ♥ LAWTON DIA x WALL |-|-| DATE CODE BRITISH DEGREASED MEDICAL

Stamped Marking R290: BS EN 13348 ♥ LAWTON DIA x WALL QUARTER YEAR BRITISH DEGREASED MEDICAL

BS EN 13348 ♥ LAWTON HARD DIA x WALL MM/YYYY MEDICAL

First Issued: 2002-05-08 Latest Issue: 2019-01-29 Effective Date: 2019-01-29 Expiry Date: 2022-01-28

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request. To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated <u>online</u>.

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK. A member of BSI Group of Companies.